
LIGHTING GENERAL NOTES


- 1.) ALL PROPOSED LIGHTING UNITS SHALL BE LABELED ACCORDING TO THE STANDARD SPECIFICATIONS, WITH POLE NUMBERS ATTACHED WITH STAINLESS STEEL BANDING. LIGHTING UNIT NUMBERING SHALL BE AS DIRECTED BY THE ENGINEER.
- 2.) CONTRACTOR SHALL BE RESPONSIBLE TO COORDINATE ELECTRICAL WORK WITH OTHER TRADES.
- 3.) THE CONTRACTOR IS RESPONSIBLE FOR UNCOVERING OR HAND DIGGING AROUND UTILITIES AS NECESSARY. THE COST OF THIS WORK IS TO BE INCLUDED WITH THE "UNIT DUCT, 600V, 2-1C NO.4, 1/C NO.6 GROUND, (XLP-TYPE USE), 1" DIA POLYETHYLENE" PAY ITEM.
- 4.) ALL PROPOSED LIGHT POLES TO BE INSTALLED AT A MINIMUM OF 15 FEET BEHIND THE EDGE OF PAVEMENT. NO POLES TO BE INSTALLED IN THE FLOWLINE OF DITCH. POLE SETBACK TO BE INCREASED IF NECESSARY AS DIRECTED BY THE ENGINEER.
- 5.) NO LIGHTING CIRCUIT OR PORTION THEREOF SHALL BE REMOVED FROM NIGHTTIME OPERATION WITHOUT APPROVAL OF THE ENGINEER.
- 6.) THE CONTRACTOR SHALL BE RESPONSIBLE FOR MAINTAINING THE LIGHTING SYSTEM UNTIL IDOT HAS TAKEN ACCEPTANCE OF THE SYSTEM. ALL EXISTING CIRCUITS AND CABLES TO THE LIGHT POLES SHALL BE MAINTAINED AS NEEDED AND THIS WORK SHALL BE INCIDENTAL TO THE CONTRACT.
- 7.) ALL ATTACHED CONDUIT, JUNCTION BOXES, CONDUIT HANGERS, SUPPORTS AND APPURTENANCES SHALL BE REMOVED FROM THE BRIDGE, REMOVED MATERIALS SHALL BECOME THE PROPERTY OF THE CONTRACTOR AND SHALL BE DISPOSED OF ACCORDING TO ARTICLE 202.03. THE COST OF THIS WORK SHALL BE INCLUDED IN THE BRIDGE REMOVAL, AND NO ADDITIONAL PAYMENT WILL BE ALLOWED.
- 8.) ALL EXISTING LIGHTING UNITS, EXCEPT 7G AND BI5 AS SHOWN ON THE PLANS, SHALL REMAIN FULLY OPERATIONAL DURING STAGE 1 CONSTRUCTION. ALL LIGHTING UNITS ON CIRCUIT 1-2 SHALL BE INSTALLED AND MADE FULLY OPERATIONAL PRIOR TO STAGE 2 CONSTRUCTION.
- 9.) THE CONTRACTOR SHALL TAKE INSULATION RESISTANCE MEASUREMENTS OF ALL EXISTING CIRCUITS BEFORE ANY MODIFICATIONS ARE MADE AND PROVIDE THE WRITTEN RESULTS TO THE ENGINEER. EXISTING CIRCUITS IN THE LIGHTING CONTROLLERS LOCATED AT STA. 327+70 AND STA. 349+00 NOT TESTED AND PROPERLY DOCUMENTED SHALL BE SUBJECT TO THE INSULATION REQUIREMENTS OF ARTICLE 801.13 AT THE CONTRACTOR'S EXPENSE.
- 10.) THE CONTRACTOR SHALL TAKE INSULATION RESISTANCE MEASUREMENTS OF THE EXISTING PORTION OF THE CIRCUIT FED FROM THE EXISTING CONTROLLER AT STA. 349+00 PRIOR TO CONNECTING THE NEW FACILITIES TO THIS CIRCUIT. WRITTEN RESULTS SHALL BE PROVIDED TO THE ENGINEER.
- 11.) AFTER THE PROPOSED CIRCUITS ARE FULLY INSTALLED THE CONTRACTOR SHALL TAKE INSULATION RESISTANCE MEASUREMENTS ACCORDING TO ARTICLE 801.13 AND PROVIDE THE WRITTEN RESULTS TO THE ENGINEER. IF THE TEST RESULTS DO NOT COMPLY WITH ARTICLE 801.13, THE CONTRACTOR SHALL THEN TEST ONLY THE PORTIONS OF THE CIRCUIT WHICH ARE NEW. ANY WORK NECESSARY TO BRING THE CIRCUITS INTO COMPLIANCE SHALL BE AT THE CONTRACTOR'S OWN EXPENSE AND NO ADDITIONAL PAYMENT WILL BE ALLOWED.
- 12.) THE CONTRACTOR SHALL PLACE A COPY OF REVISED AS-BUILT PLANS INSIDE THE EXISTING LIGHTING CONTROLLERS LOCATED AT STA. 327+70 AND STA. 349+00.
- 13,) THE LOCATIONS OF ALL EXISTING LIGHTING FACILITIES SHOWN ON THE PLANS ARE APPROXIMATE. THE CONTRACTOR SHALL VERIFY EXISTING FIELD CONDITIONS.
- 14.) PROPOSED LIGHT POLE FOUNDATION SHALL BE

 flugh with the existing grade and shall weet the height requirements of Article 836.03 of the Standard Specifications. After unit duct is installed, foundations shall be filled with fine aggregate according to Article 836.03. Washers used to install the pole shall be large enough to fully cover the slotted holes in the pole base plate.

 15.) Underground Conduit, Coilable Nonwetallic Conduit, 2 1/2" Dia. Shall be Schedule 80 as noted in the plans.




underground Conduit, Coilable Foot 182 Normotallic Conduit, 21/2" Dia.



63 | 63 | 50A|240V | 2P) =

LIGHTING CKT 2-1 EXISTING LIGHTING CONTROLLER NORTH SIDE OF IL 13, EAST OF THE BRIDGE



LIGHTING CKT 2-2 EXISTING LIGHTING CONTROLLER NORTH SIDE OF IL 13, EAST OF THE BRIDGE

NOTES

1.) ALL NECESSARY REVISIONS TO THE WIRING SHOWN ON THIS SHEET SHALL BE MADE AT NO ADDITIONAL COST TO THE DEPARTMENT AND TO THE SATISFACTION OF THE ENGINEER.

2.1 EXISTING POLE NUMBERS ARE BASED ON THE AS-BUILT PLANS.

3.) CONTRACTOR SHALL VERIFY THE RATING OF ALL BRANCH CIRCUIT BREAKERS IN THE EXISTING CONTROLLER LOCATED AT STA. 349+00. LARGER BREAKERS SHALL BE FURNISHED AND INSTALLED IF NEEDED ACCORDING TO NEC REQUIREMENTS. THIS WORK SHALL BE PAID FOR ACCORDING TO ARTICLE 109.04.

LIGHTING CIRCUIT LEGEND

---- EXISTING ELECTRIC CABLE

EXISTING HANDHOLE

EXISTING 250W HPS LUMINAIRE

EXISTING 700W MV LUMINAIRE

PROPOSED 250W HPS LUMINAIRE

LIGHTING CIRCUITS

															1
FILE NAME :	USER NAME = defoult	DESIGNED -	REVISED -			LIGHTING PLANS						SECTION	COUNTY	TOTAL SHEE SHEETS NO.	П
m(\28818\m;c-r+totion\2phase;;\0478856-s	rt-lightudgn	DRAWN -	REVISED -	STATE OF ILLINOIS		CENIEDAI MOTEC	VERAL NOTES, QUANTITIES, AND			DOME THAT THE	331	(12-1)8-1	JACKSON	200 44	7
	PLOT SCALE = 100.0000 '/ IN.	CHECKED ~	REVISED -	DEPARTMENT OF TRANSPORTATION		GLITHIAL INDILG				HOOH DIAGHANG			CONTRAC	CT NO. 78056	5
	PLDT DATE = 1/25/2012	DATE -	REVISED -		SCALE:	SHEET NO. 1	OF 7 SH	EETS	STA.	TO STA,		ILLINOIS FE	D. AID PROJECT	***************************************	